

WELL CONSTRUCTOR'S REPORT

DEPARTMENT OF RESOURCE DEVELOPMENT

1. COUNTY Crawford CHECK ONE Town Village City NAME Steuben

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.) NW 1/4 of Sec. 9 Lot 21 Block 1 sec 9 T8, R9W

3. OWNER AT TIME OF DRILLING Steuben Ball Park

4. OWNER'S COMPLETE MAIL ADDRESS agent Noel Daugherty, Steuben, Wis., 54657

5. Distance in feet from well to nearest: BUILDING SANITARY SEWER FLOOR DRAIN FOUNDATION DRAIN WASTE WATER DRAIN
(Record answer in appropriate block) 15' C.I. TILE C.I. TILE SEWER CONNECTED INDEPENDENT C.I. TILE

CLEAR WATER DRAIN SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE
C.I. TILE 75'

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Ball Park

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>6</u>	<u>Surface</u>	<u>64</u>				<u>loose sand</u>	<u>Surface</u>	<u>50</u>
						<u>gravel bed</u>	<u>50</u>	<u>64</u>

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain ends 19.18</u>	<u>Surface</u>	<u>64</u>

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
<u>loose sand</u>	<u>Surface</u>	<u>50</u>

11. MISCELLANEOUS DATA

Well construction completed on 7-18-1968

Yield test: 6 Hrs. at 15 GPM Well is terminated 8 inches above below final grade

Depth from surface to normal water level 30 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 33 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison, Wis. laboratory on: Oct. 23-1968

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Herbert Cyprian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis. 53805

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
<u>5420</u>				

Please do not write in space below