

NOTE:

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Marietta</u>		
2. LOCATION 1/4 Section <u>NE</u> Section <u>10</u> Township <u>8 N</u> Range <u>4 W</u>		3. NAME <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Jerry Schlaemer</u>		ADDRESS <u>R. 3 D</u>		
OR - Grid or Street No. _____ Street Name _____		AND - If available subdivision name, lot & block No. _____		POST OFFICE <u>Stephens, Wis. 54657</u>		
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>8'</u>	Sanitary Bldg. Drain C.I. <u>20'</u> Other _____	Sanitary Bldg. Sewer C.I. _____ Other _____	Floor Drain Connected To: C.I. Sewer _____ Other Sewer _____	
Street Sewer San. _____ Storm _____		Other Sewers C.I. _____ Other _____		Foundation Drain Connected to: Sewer _____ Sewage Sump _____ Clearwater Dr. _____	Sewage Sump C.I. _____ Other _____	
Privy _____ Pet Waste Pit _____		Pit: Nonconforming Existing _____ Well _____ Pump _____ Tank _____		Subsurface Pumproom Nonconforming Existing _____	Barn Gutter <u>300'</u> Animal Barn Pen _____ Animal Yard _____ Silo With Pit _____ Glass Lined Storage Facility _____ Silo w/o Pit _____ Earthen Silage Storage Trench Or Pit _____	
Temporary Manure Stack _____		Watertight Liquid Manure Tank _____ Solid Manure Storage Structure _____		Subsurface Gasoline or Oil Tank _____	Waste Pond or Disposal Unit (Specify Type) _____ Land _____ Other (Give Description) _____	
5. Well is intended to supply water for: <u>Farm home</u>		9. FORMATIONS				
6. DRILLHOLE		Dia. (in.)		From (ft.)	To (ft.)	
Dia. (in.)		From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10"</u>	<u>Surface</u>	<u>0</u>	<u>123'</u>	<u>6</u>	<u>123</u>	<u>135'</u>
				<u>Clay &amp; stone shalestone</u>	<u>Surface</u>	<u>60</u>
				<u>sandstone</u>	<u>60</u>	<u>100</u>
					<u>100</u>	<u>135</u>
7. CASING, LINER, CURBING AND SCREEN		Material, Weight, Specification & Method of Assembly				
Dia. (in.)		From (ft.)		To (ft.)		
<u>6</u>	<u>new black steel P.E. 18.97 A. 53</u>	<u>Surface</u>	<u>0</u>	<u>123</u>		
<u>Valley Steel</u>		<u>Pitless adaptor</u>				
8. GROUT OR OTHER SEALING MATERIAL		10. TYPE OF DRILLING MACHINE USED				
Kind		From (ft.)		To (ft.)		
<u>Clay</u>	<u>Surface</u>	<u>0</u>	<u>7</u>			
<u>Cement</u>	<u>Surface</u>	<u>7</u>	<u>123</u>			
11. MISCELLANEOUS DATA		Well construction completed on <u>Nov. 18 -</u> 19 <u>77</u>				
Yield Test: <u>3</u> Hrs. at <u>5</u> GPM		Well is terminated <u>10</u> inches		<input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Depth from surface to normal water level <u>65</u> Ft.		Well disinfected upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <u>72</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <u>Madison</u> laboratory on <u>Nov. 21</u> 19 <u>77</u>		Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.				
Signature <u>Kenneth Coplan</u> Registered Well Driller		Complete Mail Address <u>R3 Box 84 Boscobel, Wis. 53805</u>				

547