

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME St. Town Hall  
 2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
Block 1 Lot 20-21-22 Sec. 16 Range 4-B W Town 8 N

3. OWNER AT TIME OF DRILLING Agent - Lester Daugherty Noell  
 4. OWNER'S COMPLETE MAIL ADDRESS Steuben, Wis.

5. Distance in feet from well to nearest: (Record answer in appropriate block)	BUILDING	SANITARY	SEWER	FLOOR DRAIN	FOUNDATION DRAIN		WASTE WATER DRAIN	
	<u>in side</u>	C. I.	TILE	C. I.	TILE	SEWER CONNECTED	INDEPENDENT	C. I. TILE
								<u>25'</u>
CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C. I. TILE								
<u>25'</u>	<u>75'</u>	<u>0</u>	<u>80'</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)  
0

6. Well is intended to supply water for: Village Hall or Town Hall

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>6"</u>	<u>Surface</u>	<u>90'</u>				<u>Clay</u>	<u>Surface</u>	<u>20</u>
						<u>soft sandstone</u>	<u>20</u>	<u>38</u>
						<u>hard shalestone</u>	<u>38</u>	<u>90</u>

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6"</u>	<u>Standard wt.</u>	<u>Surface</u>	<u>47'</u>
	<u>#19.18 new black steel plain end</u>		
<u>Casing was driven thru loose formation into hard shalestone</u>			

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
<u>Clay &amp; sand</u>	<u>Surface</u>	<u>38</u>
<u>Cement</u>	<u>20</u>	<u>47</u>

11. MISCELLANEOUS DATA	
Yield test: <u>5</u> Hrs. at <u>20</u> GPM	Well is terminated <u>8</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth from surface to normal water level <u>25</u> ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping <u>25</u> ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to Madison laboratory on: Sept. 21 1966

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Pajian COMPLETE MAIL ADDRESS R3 Box 36 Boacohel, Wis. 53805  
 Registered Well Driller

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
<u>553</u>				