

1. COUNTY Crawford CHECK ONE Town Village City NAME Steuben

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
Lot 10 Block 2 Village of Steuben

3. OWNER AT TIME OF DRILLING Richard O. Boyd Section 10-T. 8N. R 4-W. RECEIVED

4. OWNER'S COMPLETE MAIL ADDRESS Steuben, Wis. APR 25 1966

5. Distance in feet from well to nearest: BUILDING SANITARY SEWER FLOOR DRAIN FOUNDATION DRAIN WASTE WATER DRAIN
(Record answer in appropriate block) 35' C. I. TILE C. I. TILE SEWER CONNECTED INDEPENDENT SANITARY TILE ENGINEER

CLEAR WATER DRAIN SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE
C. I. TILE 50' 50' 0 65' 0 0 0 0

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)
0

6. Well is intended to supply water for: home

7. DRILLHOLE 10. FORMATIONS

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>6"</u>	<u>Surface</u>	<u>110</u>			<u>110'</u>	<u>Clay</u>	<u>Surface</u>	<u>55</u>
						<u>loose sand</u>	<u>55</u>	<u>80</u>
						<u>hard shalestone</u>	<u>80</u>	<u>110</u>

8. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6"</u>	<u>Standard wt</u> <u>Wt?</u>	<u>Surface</u>	<u>88</u>
	<u>#19, 18</u>		

Casing was driven thru loose formation into hard shalestone

9. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>55</u>

Well construction completed on Feb. 17 1966

11. MISCELLANEOUS DATA

Yield test: 5 Hrs. at 15 GPM Well is terminated 10 inches above below final grade

Depth from surface to normal water level 60 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 60 ft. Well sealed watertight upon completion Yes No

Water sample sent to 4-19-66 Madison, Wis. laboratory on: 4-19 1966

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Herbert Coplan COMPLETE MAIL ADDRESS R3 Box 36 Boonville, Wis. 53805
Registered Well Driller

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
<u>554</u>				