

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Marietta</u>	
2. LOCATION OR - Grid or Street No. <u>SW</u> Section <u>17</u> Township <u>8N</u> Range <u>5W</u> <u>(4)</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Harvey Peterson</u>			
AND - If available subdivision name, lot & block No.		ADDRESS <u>R 7 D</u> POST OFFICE <u>Steuben, Wis., 54657</u>			
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>8'</u>		Building		Sanitary Bldg. Drain	
		Sanitary Bldg. Sewer		Floor Drain Connected To:	
		Storm Bldg. Drain		Storm Bldg. Sewer	
		C.I. Other		C.I. Sewer Other Sewer	
		C.I. Other		C.I. Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:	
San. Storm C.I. Other		Sewer		Sewage Sump	
		Clearwater Dr.		Clearwater Sump	
				Septic Tank, Holding Tank	
				Sewage Absorption Unit <u>75'</u>	
				Seepage Pit	
				Seepage Bed	
				Seepage Trench	
Privy		Pet Waste Pit		Pit: Nonconforming Existing	
				Subsurface Pumproom	
				Nonconforming Existing	
				Barn Gutter	
				Animal Barn Pen	
				Animal Yard	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit	
				Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
				Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)	
				Other (Give Description)	
5. Well is intended to supply water for: <u>Country homes</u>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.) From (ft.) To (ft.)			From (ft.) To (ft.)		
10 Surface 66			Clay & loose stone Surface 40		
6 66 80			limestone 40 70		
			sandstone 70 80		
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly			From (ft.) To (ft.)		
6 new black steel P.E. 18.97			Surface 66		
A-53					
Valley Steel					
Pitless adaptor					
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind From (ft.) To (ft.)			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
Clay Surface 7			Well construction completed on <u>7-22-1978</u>		
Cement 7 66			Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
11. MISCELLANEOUS DATA			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Yield Test: <u>2</u> Hrs. at <u>5</u> GPM			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth from surface to normal water level <u>35</u> Ft.					
Depth of water level when pumping <u>42</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to <u>Madison</u> laboratory on <u>8-7-1978</u>					

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller Complete Mail Address Boacohel, Wis., R3 Box 84 53805