

MAY 9 1977

State of Wisconsin
Department of Natural Resources
Box 450
Madison, Wisconsin 53701

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15
Rev. 10-75

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Marietta

2. LOCATION $\frac{1}{4}$ Section SW Section 21 Township 8N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Mark A. Janicek
OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Waunakee, W.I.

4. Distance in feet from well to nearest: (Record answer in appropriate block) 20'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	
San.	Storm	C.I.	Other	Sewer	Sewage Sump	C.I.	Other				Seepage Pit	
				Clearwater Dr.	Clearwater Sump						Seepage Bed	
											Seepage Trench	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
		Well	Nonconforming Existing							
		Pump								
		Tank								

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
------------------------	-------------------------------	--------------------------------	---------------------------------	---	--------------------------

5. Well is intended to supply water for: Country Home 9. FORMATIONS

6. DRILLHOLE						Kind	From (ft.)	To (ft.)
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)			
10	0 Surface	64	6	64	270	Clay	0 Surface	15
						Limestone	15	270

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	P.E. New Black Steel Valley Steel A-53 18.97	0 Surface	64
	Titless Adaptor		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	0 Surface	7
Cement	7	64

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 200 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 205 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on May 2 19 77

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature 562 Complete Mail Address R3, Box 84 - Boscobel, WI 53805
Kenneth Coplan Registered Well Driller