

AUG 9 1977

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

NOTE:

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Kauzeke

2. LOCATION NW Section 34 Township 7N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Ben Bird

OR - Grid or Street No. Street Name 8N ADDRESS R 700

AND - If available subdivision name, lot & block No. POST OFFICE Kauzeke, Wis., 53826

4. Distance in feet from well to nearest: (Record answer in appropriate block) 20'

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected to	Storm Bldg. Drain	Storm Bldg. Sewer
C.I.	Other	C.I.	Other	C.I.	Other

Street Sewer	Other Sewers	Foundation Drain Connected to	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	C.I.	Other
							<u>80'</u>

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
		Well	Nonconforming Existing							

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>231</u>	<u>6</u>	<u>231</u>	<u>290</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18-97 A-53</u>	<u>Surface</u>	<u>231</u>
	<u>Valley Steel Pitless adaptor</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>231</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>10</u>
<u>broken limestone</u>	<u>10</u>	<u>200</u>
<u>hard limestone</u>	<u>200</u>	<u>250</u>
<u>sandstone</u>	<u>250</u>	<u>290</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drifting mud & air Jetting with

Rotary-air w/drifting mud Rotary-hammer & air Air

Rotary-w/drifting mud Reverse Rotary Water

Well construction completed on 7-19-1977

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 210 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 215 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 8-3-1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cyprian Registered Well Driller Complete Mail Address Boscobel, Wis. R3 Box 84 53805

572