

OCT 11 1976

State of Wisconsin  
Department of Natural Resources  
Box 450  
Madison, Wisconsin 53701

NOTE:

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT  
Form 3300-15  
Rev. 10-75

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Eastman

2. LOCATION 1/4 Section NE Section 10 Township 8N Range 5W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE

OR - Grid or Street No. Street Name ADDRESS R1

AND - If available subdivision name, lot & block No. POST OFFICE Steuben, Wis. 54657

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 30' Sanitary Bldg. Drain C.I. 40' Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump Clearwater Sump Sewage Absorption Unit 100' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country homes

6. DRILLHOLE

| Dia. (in.) | From (ft.)     | To (ft.)   | Dia. (in.) | From (ft.) | To (ft.)   | Kind             | From (ft.)     | To (ft.)   |           |
|------------|----------------|------------|------------|------------|------------|------------------|----------------|------------|-----------|
| <u>10</u>  | <u>Surface</u> | <u>142</u> | <u>6</u>   | <u>142</u> | <u>440</u> | <u>Clay</u>      | <u>Surface</u> | <u>0</u>   | <u>10</u> |
|            |                |            |            |            |            | <u>limestone</u> | <u>10</u>      | <u>40</u>  |           |
|            |                |            |            |            |            | <u>sandstone</u> | <u>40</u>      | <u>120</u> |           |

7. CASING, LINER, CURBING AND SCREEN

| Dia. (in.) | Material, Weight, Specification & Method of Assembly | From (ft.)     | To (ft.)   | Kind                  | From (ft.) | To (ft.)   |
|------------|------------------------------------------------------|----------------|------------|-----------------------|------------|------------|
| <u>6</u>   | <u>new black steel P.E. 18.97 A-53</u>               | <u>Surface</u> | <u>142</u> | <u>limestone</u>      | <u>120</u> | <u>360</u> |
|            | <u>Valley Steel</u>                                  |                |            | <u>hard sandstone</u> | <u>360</u> | <u>440</u> |
|            | <u>Pitless Adapter</u>                               |                |            |                       |            |            |

8. GROUT OR OTHER SEALING MATERIAL

| Kind          | From (ft.)     | To (ft.)   |
|---------------|----------------|------------|
| <u>Clay</u>   | <u>Surface</u> | <u>7</u>   |
| <u>Cement</u> | <u>7</u>       | <u>142</u> |

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

Well construction completed on 9-18- 1976

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches  above final grade  below

Depth from surface to normal water level 360 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 364 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 10-4- 1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Lopian Registered Well Driller Complete Mail Address R3 Box 84 Boscobel, Wis. 53805