

State of Wisconsin
Department of Natural Resources
Box 450
Madison, Wisconsin 53701

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15
Rev. 10-75

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman

2. LOCATION SE 11 Township 8N Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
ADDRESS Roger Fish
RI, Box 398
POST OFFICE Prairie du Chien, WI 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 45' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewage Sump C.I. Other Clearwater Sump Clearwater Dr. Sewage Sump Clearwater Sump Clearwater Dr. Septic Tank Holding Tank Sewage Absorption Unit 100' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0 Surface	66	6	66	80

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Soft Sandstone	0 Surface	50
Hard Shalestone	50	80

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	P.E. New Black Steel 18.97	0 Surface	66
	Valley Steel A-53		
	Pitless Adapter		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	0 Surface	7
Cement	7	66

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-air w/drilling mud Rotary-w/drilling mud Rotary-hammer w/drilling mud & air Reverse Rotary Jetting with Air Water

Well construction completed on Oct. 19 1976

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 6 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 25 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 48 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Nov. 2 1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address R3, Box 84, Roscoe, WI 53805