

SEP 8 1976

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Marietta</u>	
2. LOCATION 1/4 Section <u>NE</u> Section <u>16</u> Township <u>8N</u> Range <u>5W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Ora Miller</u>		ADDRESS	
OR - Grid or Street No. Street Name		POST OFFICE <u>Steuben, WI 54657</u>		AND - If available subdivision name (lot & block No.) <u>Paris addition 344</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>15'</u>	Sanitary Bldg. Drain C.I. <u>20'</u> Other	Sanitary Bldg. Sewer C.I. Other	Floor Drain Connected To: C.I. Sewer Other Sewer
Street Sewer San. Storm C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump		Clearwater Sump	Septic Tank Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench <u>70'</u>
Privy	Pet Waste Pit	Pit: Nonconforming Existing Well Pump Tank	Subsurface Pumproom Nonconforming Existing	Barn Gutter	Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
5. Well is intended to supply water for: <u>Home</u>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>77</u>	<u>6</u>	<u>77</u>	<u>100</u>
7. CASING, LINER, CURBING AND SCREEN			Material, Weight, Specification & Method of Assembly		
Dia. (in.)	From (ft.)	To (ft.)			
<u>6</u>	<u>Surface</u>	<u>77</u>	<u>new black steel P.E. 18.97 A-53 Valley Steel Pitless adaptor</u>		
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<u>Clay</u>	<u>Surface</u>	<u>7</u>	<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<u>Cement</u>	<u>7</u>	<u>77</u>	<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water
11. MISCELLANEOUS DATA			Well construction completed on <u>8-21-1976</u>		
Yield Test: <u>4</u> Hrs. at <u>5</u> GPM	Well is terminated <u>8</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth from surface to normal water level <u>60</u> Ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
Depth of water level when pumping <u>60</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to <u>Madison</u> laboratory on <u>8-30-1976</u>					

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature 603
Kenneth Copian Registered Well Driller

Complete Mail Address Boscobel, WI 53805
R3 Box 84