

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

DEC 27 1978 WELL CONSTRUCTOR'S REPORT
3300-15 Rev. 12-76

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Marietta</u>	
2. LOCATION ¼ Section <u>NW</u> Section <u>17</u> Township <u>8N</u> Range <u>5W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE		<u>George Wallin</u>	
OR - Grid or Street No. Street Name		ADDRESS <u>Box 56 Steuben</u>		POST OFFICE <u>Wv., 54657</u>	
AND - If available subdivision name, lot & block No.					
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>10'</u>		Sanitary Bldg. Drain C.I. Other		Sanitary Bldg. Sewer C.I. Other	
Floor Drain Connected To:		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump	
Sewage Sump C.I. Other		Clearwater Sump		Septic Tank <u>60</u>	
Holding Tank		Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench <u>70'</u>			
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumphoom Nonconforming Existing	
Barn Gutter		Animal Barn Pen		Animal Yard	
Silo With Pit		Glass Lined Storage Facility		Silo w/o Pit	
Earthen Silage Storage Trench Or Pit		Temporary Manure Stack		Watertight Liquid Manure Tank	
Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)	
Other (Give Description)					
5. Well is intended to supply water for: <u>home</u>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)			From (ft.) To (ft.)		
<u>10</u> <u>0</u> <u>61</u> <u>6</u> <u>61</u> <u>80</u>			<u>Surface</u> <u>0</u> <u>45</u>		
			<u>hard shalestone</u> <u>45</u> <u>70</u>		
			<u>sandstone</u> <u>70</u> <u>80</u>		
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly			From (ft.) To (ft.)		
<u>6</u> <u>new black steel</u> <u>P.E. 18.97</u>			<u>0</u> <u>Surface</u> <u>61</u>		
<u>A-53</u>					
<u>Kent steel</u>					
<u>Pitless adaptor</u>					
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind From (ft.) To (ft.)			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with		
<u>drill cuttings</u> <u>0</u> <u>8</u>			<input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air		
<u>Cement</u> <u>8</u> <u>61</u>			<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
11. MISCELLANEOUS DATA			Well construction completed on <u>12-4-</u> 19 <u>78</u>		
Yield Test: <u>3</u> Hrs. at <u>5</u> GPM			Well is terminated <u>8</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Depth from surface to normal water level <u>40</u> Ft.			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <u>48</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <u>Madison</u> laboratory on <u>12-20-</u> 19 <u>78</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>607</u> <u>Kenneth Coplan</u> Registered Well Driller			Complete Mail Address <u>Boscobel, Wv.,</u> <u>R3 Box 84</u> <u>53805</u>		