

SEP 28 1978

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Eastman	
2. LOCATION 1/4 Section NE Section 34 Township 8 N Range 5 W		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Dorothy Burgess		ADDRESS Wauzeka	
OR - Grid or Street No. Street Name		AND - If available subdivision name, lot & block No.		POST OFFICE WV. 53826	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building 30'		Sanitary Bldg. Drain C.I. Other	
		Sanitary Bldg. Sewer C.I. Other		Floor Drain Connected To: C.I. Sewer Other Sewer	
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:	
San. Storm		C.I. Other		Sewage Sump C.I. Other	
		Sewer		Clearwater Sump	
		Clearwater Dr.		Septic Tank	
		Well		Holding Tank	
		Pump		Sewage Absorption Unit 75'	
		Tank		Seepage Pit	
		Subsurface Pumproom		Seepage Bed	
		Nonconforming Existing		Seepage Trench	
Privy		Pet Waste Pit		Barn Gutter	
		Pit: Nonconforming Existing		Animal Barn Pen	
		Well		Animal Yard	
		Pump		Silo With Pit	
		Tank		Glass Lined Storage Facility	
		Subsurface Gasoline or Oil Tank		Silo w/o Pit	
		Waste Pond or Land Disposal Unit (Specify Type)		Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
				Other (Give Description)	
5. Well is intended to supply water for: Farm home			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)			From (ft.) To (ft.)		
10 Surface 0 349 6 349 435			Clay Surface 0 10		
			limestone 10 20		
			soft sandstone 20 110		
			broken limestone 110 310		
			hard sandstone 310 435		
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly					
Dia. (in.) From (ft.) To (ft.)					
6 new black steel 0 349					
R.E. 18.97 Surface					
A-53					
Valley Steel					
Pitless adaptor					
8. GROUT OR OTHER SEALING MATERIAL					
Kind From (ft.) To (ft.)					
Clay Surface 0 8					
Cement 8 349					
10. TYPE OF DRILLING MACHINE USED					
<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with					
<input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air					
<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water					
Well construction completed on 9-8-1978					
11. MISCELLANEOUS DATA					
Yield Test: 4 Hrs. at 5 GPM Well is terminated 10 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below					
Depth from surface to normal water level 350 Ft. Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Depth of water level when pumping 375 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to Madison laboratory on 9-25-1978					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature Kenneth Coplan Registered Well Driller			Complete Mail Address Boscobel, Wv. R.3 Box 84 53805		