

**WELL CONSTRUCTOR'S REPORT**  
FORM 3300-15

JUL 1973

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

**NOTE**  
WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

<b>1. COUNTY</b> Crawford	<b>CHECK ONE</b> <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City	<b>NAME</b> Eastman
------------------------------	---	------------------------

<b>2. LOCATION -</b> 1/4 Section: Gov. Lpt 3, Section: 5, Township: 8N, Range: 6W	<b>3. OWNER AT TIME OF DRILLING</b> Gaylord Smethurst
OR - Grid or street no. _____ Street name _____	<b>ADDRESS</b> Rt. 1

AND - If available subdivision name, lot & block no. \_\_\_\_\_ **POST OFFICE**  
Eastman, Wisc.

<b>4. Distance in feet from well to nearest:</b> (Record answer in appropriate block)	<b>BUILDING</b>	<b>SANITARY SEWER</b>	<b>FLOOR DRAIN</b>	<b>FOUNDATION DRAIN</b>		<b>WASTE WATER DRAIN</b>	
	C.I.	TILE	C.I.	TILE	SEWER CONNECTED	INDEPENDENT	C.I.
	66	90	None	None	None	None	None

<b>CLEAR WATER DRAIN</b>	<b>SEPTIC TANK</b>	<b>PRIVY</b>	<b>SEEPAGE PIT</b>	<b>ABSORPTION FIELD</b>	<b>BARN</b>	<b>SILLO</b>	<b>ABANDONED WELL</b>	<b>SINK HOLE</b>
C.I.	TILE							
None	200	None	220	None	None		None	

**OTHER POLLUTION SOURCES** (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)  
None

**5. Well is intended to supply water for:**  
Trailer Court

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	36				Black Dirt	Surface	6
6	36	161				Trap rock	6	36
						Drift & Sand	36	78
						Gray Limestone	78	161

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	New Steel P.E. 18.97#/ft.	Surface	82

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED			
Kind	From (ft.)	To (ft.)	<input checked="" type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	
Puddled Clay	Surface	36	<input type="checkbox"/> Rotary - air w/drilling mud	<input type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water	
Drive Shoe	36	82	Well construction completed on 7-6 1973			

11. MISCELLANEOUS DATA				Well is terminated 12 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Yield test:	5	Hrs. at 23	GPM	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth from surface to normal water level	75		ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping	90		ft.	

Water sample sent to State Lab. of Hygiene, Madison, Wisc. laboratory on: 7-11 1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

<b>SIGNATURE</b> <i>Duane Lubbers</i> W.D. 410 Registered Well Driller	<b>COMPLETE MAIL ADDRESS</b> Duane Lubbers Farmersburg, Iowa 52047
---	--

Please do not write in space below

COLIFORM TEST RESULT 627	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
-----------------------------	---------------	---------------	-----------	---------