

First Water Quality Test For
WISCONSIN UNIQUE WELL NUMBER BA 683

State of Wisconsin
 Department of Natural Resources
 Private Water Supply - WS/2
 Box 7921
 Madison, WI 53707

UG 1 1 1989

Property Owner Kenneth Harris Telephone Number
 Mailing Address R.R. 1 Hillpoint Rd.
 City Wauzeka State Wi. Zip Code 53826
 County Crawford County Well Location Permit No. W Well Completion Date 08, 08, 89
M M D D Y Y

1. Location (Please type or print using a black pen.)
 Town City Village Fire # (if available)
 of Marietta
 Grid or Street Address or Road Name and Number (if available)
 Subdivision Name Lot # Block #

Well Constructor (Business Name) Registration #
Corpiam Well Drilling 75
 Address 501 E. Oak
 City Boscobel State Wi. Zip Code 53805

2. Mark well location in correct 40-acre parcel of section.

 N
 W E
 S

Gov't Lot # SW 1/4 of SW 1/4 of
 Section 27; T 8 N; R 4 E W

3. Well Type New
 Replacement Reconstruction/Rehabilitation

of well constructed in 19
 Reason for new, reconstructed, replaced, or rehabilitated well?
Lack of water
 Drilled Driven Point Jetted Other

4. Well serves 1 of homes and/or barn
 (ex: barn, restaurant, church, school, industry, etc.)
 High Capacity Well? Yes No
 High Capacity Property? Yes No

5. Well Located on Highest Point of Property, Consistent with the General Layout and Surroundings? Yes No
 Well Located in Floodplain? Yes No
 Distance In Feet From Well To Nearest:
 1. Landfill 12
 2. Building Overhang 43
 3. Septic or Holding Tank 136
 4. Sewage Absorption Unit
 6. Nonconforming Pit
 6. Buried Home Heating Oil Tank
 7. Buried Petroleum Tank
 8. Shoreline/Swimming Pool
 9. Downspout/Yard Hydrant
 10. Privy
 11. Foundation Drain to Clearwater
 12. Foundation-Drain to Sewer
 13. Building Drain
 Cast Iron or Plastic Other
 14. Building Sewer Gravity Pressure
 Cast Iron or Plastic Other
 15. Collector Sewer
 16. Clearwater Sump
 17. Wastewater Sump
 18. Paved Animal Barn Pen
 19. Animal Yard or Shelter
 20. Silo - Type
 21. Barn Gutter
 22. Manure Pipe Gravity Pressure
 Cast Iron or Plastic Other
 23. Other Manure Storage
 Other NR 112 Waste Source
 24.

6. Drillhole Dimensions

Dia. (in.)	From (ft.)	To (ft.)
<u>106</u>	<u>surface</u>	<u>253</u>
<u>6</u>	<u>253</u>	<u>365</u>

Method of constructing upper enlarged drillhole. (If applicable more than one.)
 1. Rotary - Mud Circulation
 2. Rotary - Air
 3. Rotary - Foam
 4. Reverse Rotary
 5. Cable-tool Bit in. dia.
 6. Temp. Outer Casing 10 in. dia.
 Removed? Yes No
 If no, explain
 7. Other

9. Geology

Type, Caving/Noncaving, Color, Hardness, Etc.	From (ft.)	To (ft.)
<u>I- Dirt</u>	<u>surface</u>	<u>6</u>
<u>H- shale</u>	<u>6</u>	<u>17</u>
<u>EW- white sandrock & clay</u>	<u>17</u>	<u>113</u>
<u>FL- limestone & chev.</u>	<u>113</u>	<u>297</u>
<u>L- Limestone</u>	<u>297</u>	<u>293</u>
<u>N- sandrock</u>	<u>293</u>	<u>365</u>

7. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Mfg. & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>Newblack Steel Plain End</u>	<u>surface</u>	<u>253</u>
	<u>ERW ASTM A-53-A</u>		
	<u>6x21 #18.97</u>		
Dia. (in.)	screen type and material	From	To

10. Static Water Level
289 ft. above ground level
 ft. below ground surface
 11. Pump Test
 Pumping Level 306 ft. below surface
 Pumping at 7 GPM for 3 hours
 12. Well Is:
 Above Grade
 Below Grade
 Developed? Yes No
 Disinfected? Yes No
 Capped? Yes No

8. Grout or Other Sealing Material

Method	Kind of Sealing Material	From (ft.)	To (ft.)	Sacks Cement
<u>TRANCE</u>	<u>Neat Cement</u>	<u>surface</u>	<u>253</u>	<u>83</u>

13. Were all unused, noncomplying, or unsafe wells properly filled with sealant?
 Yes No If no, explain
 14. Signature of Well Constructor Michael D. Beindorn MAB 8-8-89
 Date Signed
 Signature of Drill Rig Operator Michael D. Beindorn MAB 8-8-89
 Date Signed

63