

AUG 3 1979

State of Wisconsin
Department of Natural Resources
Box 7921
Madison, Wisconsin 53707

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15 Rev. 12-76

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman

2. LOCATION NW 17 8N 7W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 OR - Grid or Street No. Street Name ADDRESS R1 Box 43
 AND - If available subdivision name, lot & block No. POST OFFICE Eastman, Wis. 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block) 20'

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
C.I.	Other	C.I.	Other	C.I.	Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit
San.	Storm	C.I.	Other	C.I.	Other	C.I.	Other
		Sewer	Sewage Sump				Seepage Pit
		Clearwater Dr.	Clearwater Sump				Seepage Bed
							Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank

Subsurface Pumproom Nonconforming Existing Existing

Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Trailer home

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay & stone</u>	<u>Surface</u>	<u>30</u>
<u>soft sandstone</u>	<u>30</u>	<u>100</u>
<u>hard shalestone</u>	<u>100</u>	<u>160</u>

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>116</u>	<u>6</u>	<u>116</u>	<u>160</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97</u>	<u>Surface</u>	<u>116</u>
	<u>A-53</u>		
	<u>Kent steel</u>		
	<u>Pitless adapter</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>116</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 6 GPM

Depth from surface to normal water level 90 Ft.

Depth of water level when pumping 102 Ft. Stabilized Yes No

Well construction completed on 7-14-1979

Well is terminated 10 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 7-30-1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller 640

Complete Mail Address Roscobel, Wis.
R2 Box 4
53805