

JUL 03 1978

NOTE:
 White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

AUG 01 1978

WELL CONSTRUCTOR'S REPORT
 Form 3300-15 Rev. 12-76

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Eastman</u>	
2. LOCATION ¼ Section <u>SE</u> Section <u>18</u> Township <u>8 N</u> Range <u>7 W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Jerry Ostrander</u>		ADDRESS <u>R1 Box 112A</u>	
OR - Grid or Street No. Street Name		POST OFFICE <u>Eastman, Wis., 54626</u>		AND - If available subdivision name, lot & block No. <u>(6)</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>25'</u>		Building Sanitary Bldg. Drain Sanitary Bldg. Sewer Floor Drain Connected To: Storm Bldg. Drain Storm Bldg. Sewer		C.I. Other C.I. Other C.I. Sewer Other Sewer C.I. Other C.I. Other	
Street Sewer Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit <u>75'</u>		San. Storm C.I. Other Sewer Sewage Sump Clearwater Dr. C.I. Other		Clearwater Sump Septic Tank Holding Tank Seepage Pit Seepage Bed Seepage Trench	
Privy Pet Waste Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit		Other (Give Description)	
Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type)					
5. Well is intended to supply water for: <u>Trailers home</u>			9. FORMATIONS		
6. DRILLHOLE			Kind From (ft.) To (ft.)		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10 7/8</u>	Surface	<u>8</u>	<u>6</u>	<u>8</u>	<u>155</u>
					<u>Clay</u>
					<u>loose sand</u>
					<u>sandstone</u>
					<u>limestone</u>
7. CASING, LINER, CURBING AND SCREEN			Material, Weight, Specification & Method of Assembly From (ft.) To (ft.)		
Dia. (in.)			From (ft.)	To (ft.)	
<u>6</u>	<u>new black steel P.E. 18.97 A-53 Valley Steel Pitless adaptor</u>		Surface	<u>138</u>	
8. GROUT OR OTHER SEALING MATERIAL			Kind From (ft.) To (ft.)		
<u>Clay</u>			Surface	<u>8</u>	
<u>loose sand</u>			<u>8</u>	<u>110</u>	
10. TYPE OF DRILLING MACHINE USED			Well construction completed on <u>6-20-</u> 19 <u>78</u>		
<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-air w/drilling mud <input type="checkbox"/> Rotary-w/drilling mud			<input type="checkbox"/> Rotary-hammer w/drilling mud & air <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Reverse Rotary		
<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water			Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
11. MISCELLANEOUS DATA			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Yield Test: <u>3</u> Hrs. at <u>4</u> GPM			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth from surface to normal water level <u>70</u> Ft.					
Depth of water level when pumping <u>92</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to <u>Madison</u> laboratory on <u>6-27-</u> 19 <u>78</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>Kenneth Coplan</u> Registered Well Driller			Complete Mail Address <u>Boscobel, Wis. R3 Box 84 53805</u>		

642