

AUG 14 1978

State of Wisconsin  
Department of Natural Resources  
Box 7921  
Madison, Wisconsin 53707

NOTE:

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT  
Form 3300-15 Rev. 12-76

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Eastman

2. LOCATION 1/4 Section NW Section 23 Township 8N Range 9W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Dulwayne Johnson

OR - Grid or Street No. Street Name (6) ADDRESS Box 91A R1

AND - If available subdivision name, lot & block No. POST OFFICE Eastman, Wis., 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 35'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer  San.  Storm  Other Sewers  C.I.  Other  Foundation Drain Connected to: Sewer  Clearwater Dr.  Sewage Sump  Clearwater Sump  Sewage Sump  Clearwater Sump

Clearwater Sump  Septic Tank  Holding Tank  Sewage Absorption Unit 110'

Seepage Pit  Seepage Bed  Seepage Trench

Privy  Pet Waste Pit  Pit: Nonconforming Existing  Well  Pump  Tank  Subsurface Pumproom  Nonconforming Existing  Barn Gutter  Animal Barn Pen  Animal Yard  Silo With Pit  Glass Lined Storage Facility  Silo w/o Pit  Earthen Silage Storage Trench Or Pit

Temporary Manure Stack  Watertight Liquid Manure Tank  Solid Manure Storage Structure  Subsurface Gasoline or Oil Tank  Waste Pond or Land Disposal Unit (Specify Type)  Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>240</u>	<u>6</u>	<u>240</u>	<u>480</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>15</u>
<u>limestone</u>	<u>15</u>	<u>140</u>
<u>soft sandstone</u>	<u>140</u>	<u>210</u>
<u>limestone</u>	<u>210</u>	<u>450</u>
<u>hard sandstone</u>	<u>450</u>	<u>480</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel</u> <u>RF, 18.97</u> <u>A-53</u> <u>Kent Steel</u> <u>Pitless adaptor</u>	<u>Surface</u>	<u>240</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-air w/drilling mud  Rotary-w/drilling mud  Rotary-hammer w/drilling mud & air  Rotary-hammer & air  Reverse Rotary  Jetting with  Air  Water

Well construction completed on 8-3- 19 78

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>240</u>

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 382 Ft.

Depth of water level when pumping 4.05 Ft. Stabilized  Yes  No

Well is terminated 10 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 8-8- 19 78

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cospian Registered Well Driller 647 Complete Mail Address Boscobel, Wis.  
R3 Box 84 53805