

MAY 25 1976

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

NOTE  
WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Eastman

2. LOCATION - 1/4 Section SW Section 31 Township 8N Range 7W  
OR - Grid or street no. Street name (6)  
3. OWNER AT TIME OF DRILLING Glen McCullick  
ADDRESS RFD

AND - If available subdivision name, lot & block no. POST OFFICE Prairie du Chien Wis 53821

4. Distance in feet from well to nearest:  
(Record answer in appropriate block)

BUILDING C.I. 10' SANITARY SEWER TILE 25' FLOOR DRAIN C.I. 25' TILE FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT WASTE WATER DRAIN C.I. TILE  
CLEAR WATER DRAIN C.I. TILE SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE  
70' 80'

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE 9. FORMATIONS

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	144	6	144	200	Clay	Surface	10
						limestone	10	100
						soft sandstone	100	120
						limestone	120	200

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain ends 18.97	Surface	144
	A-53		
	Valley Steel		
	Pitless Adapter		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	7
Cement	7	144

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary  
 Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with Air  Water

Well construction completed on 5-4-1976

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 6 GPM

Well is terminated 12 inches  above  below final grade

Depth from surface to normal water level 150 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 152 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 5-17-1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphouses, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boscobel  
R3 Box 84 Wis. 53805

COLIFORM TEST RESULT 654 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS  
REV. 3-71