

1. COUNTY Crawford CHECK ONE Town Village City NAME Eastman

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
NE 1/4 of Sec 31 T8N R2W

3. OWNER AT TIME OF DRILLING Mr. Wencil Slama

4. OWNER'S COMPLETE MAIL ADDRESS R7D1 Prairie du Chien, Wis.

5. Distance in feet from well to nearest:

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C. I.	TILE
	30'		30'			30'	

CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
	85'			100'	130'	130'	90'	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm home

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	355	6	355	520	Clay	Surface	60	
						lime rock	60	100	
						sandrock	100	220	
						limestone	220	300	
						sandstone	300	325	
						lime stone	325	420	
						sandstone	420	520	

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	355

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	60
Cement	60	355

11. MISCELLANEOUS DATA

Yield test: 12 Hrs. at 11 GPM

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 450 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 460 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 9-3- 1969

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coyman Registered Well Driller COMPLETE MAIL ADDRESS 53805 R3 Box 84 Boscobel, Wis.

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
657				