

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Eastman  
 2. LOCATION SE 36 8N 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
 OR - Grid or Street No. Street Name ADDRESS Richard DuCharme  
 AND - If available subdivision name, lot & block No. POST OFFICE Eastman, Wis

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 50 Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other  
 Street Sewer Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit  
 San. Storm C.I. Other Sewer Sewage Sump Clearwater Dr. Clearwater Sump C.I. Other 60 Seepage Pit Seepage Bed Seepage Trench 80  
 Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit  
 Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: farm

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	81			
6	81	504			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay	Surface	7
galena lime	7	71
gray rock	71	83
Blue rock	83	92
Oil rock	92	105
Preter limestone	105	160
shale	160	168
St Peter Sandstone	168	260
shale	260	263
May lime	263	504

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6"	New Steel T & C 19.45	Surface	81
	A-53 pump town		

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water  
 Rotary-air w/drilling mud  Rotary-hammer & air  
 Rotary-w/drilling mud  Reverse Rotary

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement	Surface	81

Well construction completed on 2-14 1978

11. MISCELLANEOUS DATA  
 Yield Test: 2 Hrs. at 25 GPM Well is terminated 8 inches  above final grade  below  
 Depth from surface to normal water level 345 Ft. Well disinfected upon completion  Yes  No  
 Depth of water level when pumping 380 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on Mar 23 1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Ralph J. Faherty Registered Well Driller Complete Mail Address **FAHERTY DRILLING CO., INC.**  
 1120 Broadway  
 PLATTEVILLE, WISCONSIN 53818