

OCT 20 1976

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Scott</u>	
2. LOCATION 1/4 Section <u>SE</u> Section <u>2</u> Township <u>9N</u> Range <u>3W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE		<u>Willard Dille</u>	
OR - Grid or Street No. Street Name		ADDRESS <u>RFD</u>		POST OFFICE <u>Blue River, Wv. 53518</u>	
AND - If available subdivision name, lot & block No.					
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>20'</u>		Sanitary Bldg. Drain C.I. <u>25'</u> Other	
		Sanitary Bldg. Sewer C.I.		Floor Drain Connected To: C.I. Sewer Other Sewer	
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.		Sewage Sump C.I. Other	
		Clearwater Sump		Septic Tank <u>55'</u> Holding Tank	
		Sewage Absorption Unit <u>80'</u>		Seepage Pit Seepage Bed Seepage Trench	
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing	
Barn Gutter		Animal Barn Pen		Animal Yard	
Silo With Pit		Glass Lined Storage Facility		Silo w/o Pit	
Earthen Silage Storage Trench Or Pit		Other (Give Description)			
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)			
5. Well is intended to supply water for: <u>Country home</u>		9. FORMATIONS			
6. DRILLHOLE		Kind		From (ft.) To (ft.)	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)		<u>Clay</u>		<u>0</u> <u>5</u>	
<u>10</u> <u>0</u> <u>44</u> <u>6</u> <u>44</u> <u>100</u>		<u>shalestone</u>		<u>5</u> <u>40</u>	
		<u>hard sandstone</u>		<u>40</u> <u>100</u>	
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly		From (ft.) To (ft.)			
<u>6</u> <u>new black steel</u> <u>P.E. 18.97</u>		<u>0</u> <u>44</u>			
<u>A-53</u>					
<u>Valley Steel</u>					
<u>Pitless adaptor</u>					
8. GROUT OR OTHER SEALING MATERIAL		10. TYPE OF DRILLING MACHINE USED			
Kind From (ft.) To (ft.)		<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with			
<u>Clay</u> <u>0</u> <u>7</u>		<input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air			
<u>Cement</u> <u>7</u> <u>44</u>		<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water			
11. MISCELLANEOUS DATA		Well construction completed on <u>9-12-1976</u>			
Yield Test: <u>3</u> Hrs. at <u>6</u> GPM		Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below			
Depth from surface to normal water level <u>45</u> Ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth of water level when pumping <u>48</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Water sample sent to <u>Madison</u> laboratory on <u>10-12-1976</u>					

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller Complete Mail Address Bozabel, Wv. R3 Box 84 53805