

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

DEC 26 1973

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Scott

2. LOCATION - 1/4 Section NE Section 3 Township 9N Range 3W

OR - Grid or street no. Street name

3. OWNER AT TIME OF DRILLING William Benson  
ADDRESS R2  
POST OFFICE Gay Mills, Wis., 54631

AND If available subdivision name, lot & block no.

4. Distance in feet from well to nearest:

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE
<u>10'</u>	<u>20'</u>					

(Record answer in appropriate block)

CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
	<u>65'</u>			<u>85'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>42</u>	<u>6</u>	<u>42</u>	<u>100</u>	<u>Clay</u>	<u>Surface</u>	<u>20</u>	
						<u>Clay &amp; loose stone</u>	<u>20</u>	<u>27</u>	
						<u>hard shale stone</u>	<u>27</u>	<u>60</u>	
						<u>sandstone</u>	<u>60</u>	<u>100</u>	

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>42</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>20</u>
<u>Cement</u>	<u>20</u>	<u>42</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary  
 Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water

Well construction completed on 12-1- 19 73

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 5 GPM

Well is terminated 12 inches  above  below final grade

Depth from surface to normal water level 60 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 62 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 12-17- 19 73

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boscobel R3 Box 84 Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>676</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------

REV. 3-71