

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

NOV 20 1972

11075 ✓

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Scott

2. LOCATION - 1/4 Section SE Section 5 Township 9N Range 3W 3. OWNER AT TIME OF DRILLING David Dieckman

OR - Grid or street no. Street name ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Gay Mills, Wis. 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C. I.	TILE
<u>8'</u>	<u>60'</u>	<u>60'</u>					

CLEAR WATER DRAIN C. I.	TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		<u>70'</u>			<u>85'</u>	<u>200'</u>		<u>50'</u>	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country farm

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>141</u>	<u>6</u>	<u>141</u>	<u>330</u>	<u>Clay</u>	<u>Surface</u>	<u>15</u>
						<u>limestone</u>	<u>15</u>	<u>125</u>
						<u>Clay & stone</u>	<u>125</u>	<u>130</u>
						<u>blue limestone</u>	<u>130</u>	<u>300</u>
						<u>sandstone</u>	<u>300</u>	<u>330</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>141</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>15</u>
<u>Cement</u>	<u>15</u>	<u>141</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 11-1-1972

11. MISCELLANEOUS DATA

Yield test: 2 Hrs. at 8 GPM

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 280 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 285 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 11-15-1972

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boocobel R3 Box 84 Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>678</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------

REV. 3-71