

DEC 16 1974

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Scott

2. LOCATION - 1/4 Section SE Section 8 Township T9N Range R3W 3. OWNER AT TIME OF DRILLING Joe Miller

OR - Grid or street no. Street name ADDRESS

AND - If available subdivision name, lot & block no. POST OFFICE Mt Zion

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	TILE	C. I.	SEWER CONNECTED	INDEPENDENT

CLEAR WATER DRAIN SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE

C. I.	TILE							

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	304				Clay	Surface	6
6	304	404				Mag lime	6	190
7. CASING, LINER, CURBING, AND SCREEN								
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)				
6"	New Steel + C 19.18		Surface	304		Halesville Sand	190	320
						Lime	320	355
						Trenpelus Sandstone	355	404

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement	Surface	304

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary

Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 9/30 1974

11. MISCELLANEOUS DATA

Yield test: 2 Hrs. at 18 GPM

Well is terminated 8 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Depth from surface to normal water level 245 ft.

Depth to water level when pumping 320 ft.

Water sample sent to Madison laboratory on: Nov 26 1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Ralph Faherty Registered Well Driller COMPLETE MAIL ADDRESS FAHERTY DRILLING CO., INC.
1120 Broadway
PLATTEVILLE, WISCONSIN 53818

COLIFORM TEST RESULT 684 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED

REMARKS 53818

REV. 3-71