

1. COUNTY Crawford CHECK ONE Town Village City NAME Scott

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
N.W. of Sec. 16 T9N R3W

3. OWNER AT TIME OF DRILLING David Helfner

4. OWNER'S COMPLETE MAIL ADDRESS R 7 D Boscobel

5. Distance in feet from well to nearest: BUILDING SANITARY SEWER FLOOR DRAIN FOUNDATION DRAIN WASTE WATER DRAIN
 (Record answer in appropriate block) 25' C.I. TILE C.I. TILE SEWER CONNECTED INDEPENDENT C.I. TILE

CLEAR WATER DRAIN SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE
 C.I. TILE 0 75 0 0 0 0 0 0

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.) 0

6. Well is intended to supply water for: Home

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>80</u>	<u>6</u>	<u>80</u>	<u>100</u>	<u>Clay & loose stone</u>	<u>Surface</u>	<u>40</u>	
						<u>loose limestone</u>	<u>40</u>	<u>70</u>	
						<u>hard limestone</u>	<u>70</u>	<u>100</u>	

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>black-plain end 19.18</u>	<u>Surface</u>	<u>80</u>

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>40</u>
<u>Cement</u>	<u>40</u>	<u>80</u>

11. MISCELLANEOUS DATA
 Yield test: 5 Hrs. at 12 GPM Well construction completed on July 14 1967
 Well is terminated 12 inches above below final grade

Depth from surface to normal water level 85 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 87 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 7-18 1967

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan COMPLETE MAIL ADDRESS R3 Box 36 Boscobel, Wis. 53805
 Registered Well Driller

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
<u>699</u>				