

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

AUG 19 1977 WELL CONSTRUCTOR'S REPORT
 Form 3300-15 Rev. 12-76

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Scott

2. LOCATION 1/4 Section NW Section 19 Township 9N Range 3W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Bryce Collins

OR - Grid or Street No. Street Name ADDRESS R2

AND - If available subdivision name, lot & block No. POST OFFICE Gays Mills, Wis. 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) 35'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer: San. Storm C.I. Other
 Other Sewers: C.I. Other
 Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.
 Sewage Sump: C.I. Other
 Clearwater Sump
 Septic Tank: 130'
 Holding Tank
 Sewage Absorption Unit: 150'
 Seepage Pit
 Seepage Bed
 Seepage Trench

Privy: Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank
 Subsurface Pumproom: Nonconforming Existing
 Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>126</u>	<u>6</u>	<u>126</u>	<u>310</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>10</u>
<u>soft sandstone</u>	<u>10</u>	<u>35</u>
<u>Clay</u>	<u>35</u>	<u>65</u>
<u>broken limestone</u>	<u>65</u>	<u>100</u>
<u>hard limestone</u>	<u>100</u>	<u>280</u>
<u>sandstone</u>	<u>280</u>	<u>310</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53</u>	<u>Surface</u>	<u>126</u>

Valley Steel
Pitless adaptor

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>126</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 8-11-1977

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 260 Ft.

Depth of water level when pumping 280 Ft. Stabilized Yes No

Well is terminated 10 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 8-15-1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boscobel, Wis. R3 Box 84 53805