

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

OCT 22 1971

1. COUNTY <i>Crawford</i>		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			NAME <i>Scott</i>	
2. LOCATION - 1/4 Section <i>NW</i> Section <i>27</i> Township <i>9N</i> Range <i>3W</i>		3. OWNER AT TIME OF DRILLING <i>Dr. Howard M. Templeton</i>				
OR - Grid or street no.		Street name			ADDRESS <i>R7W</i>	
AND - If available subdivision name, lot & block no.		POST OFFICE <i>Boscobel, Wis. 53805</i>				
4. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING 6'	SANITARY SEWER C.I. 40'	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	WASTE WATER DRAIN C.I. 40'
CLEAR WATER DRAIN C.I.	SEPTIC TANK 65'	PRIVY	SEEPAGE PIT	ABSORPTION FIELD 75'	BARN 150'	SILO
				ABANDONED WELL		SINK HOLE
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)						

5. Well is intended to supply water for: *Country home*

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	40	6	40	90	Clay	Surface	10	
						loose stone & clay	10	30	
7. CASING, LINER, CURBING, AND SCREEN						Hard shale stone			
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)					
6	new black steel plain end 19.18		Surface	40		sandstone	75	90	

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED			
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	
Clay	Surface	10	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with Air <input type="checkbox"/> Water	
Cement	10	40	Well construction completed on <i>10-14-1971</i>			

11. MISCELLANEOUS DATA		Yield test: <i>3</i> Hrs. at <i>12</i> GPM		Well is terminated <i>10</i> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade	
Depth from surface to normal water level		<i>15</i> ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth to water level when pumping		<i>22</i> ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

Water sample sent to *Madison* laboratory on: *10-19-1971*

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Benneth Coprian</i>	Registered Well Driller	COMPLETE MAIL ADDRESS <i>R3 Bo 84 Boscobel, Wis. 53805</i>
-------------------------------------	-------------------------	---

COLIFORM TEST RESULT <i>714</i>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
REV. 3-71	Please do not write in space below			