

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Scott

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
N 6 1/2 Sec 33 - T 9 N. R 3 West

3. OWNER AT TIME OF DRILLING Herald Myers

4. OWNER'S COMPLETE MAIL ADDRESS Boscobel wisc R-1

5. Distance in feet from well to nearest:

|                   |                |                |                  |                   |
|-------------------|----------------|----------------|------------------|-------------------|
| BUILDING          | SANITARY SEWER | FLOOR DRAIN    | FOUNDATION DRAIN | WASTE WATER DRAIN |
| 20                | C. I.          | TILE           | C. I.            | TILE              |
|                   |                |                | SEWER CONNECTED  | INDEPENDENT       |
| CLEAR WATER DRAIN | SEPTIC TANK    | PRIVY          | SEEPAGE PIT      | ABSORPTION FIELD  |
| C. I.             | TILE           |                |                  |                   |
|                   | 60             |                |                  |                   |
| BARN              | SILLO          | ABANDONED WELL | SINK HOLE        |                   |

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm use

7. DRILLHOLE

| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) |
|------------|------------|----------|------------|------------|----------|
| 10"        | Surface    | 170      | 6"         | 170        | 303      |

10. FORMATIONS

| Kind       | From (ft.) | To (ft.) |
|------------|------------|----------|
| Clay -     | Surface    | 30       |
| Lime Stone | 30         | 165      |
| Sandstone  | 165        | 303      |

8. CASING, LINER, CURBING, AND SCREEN

| Dia. (in.) | Kind and Weight   | From (ft.) | To (ft.) |
|------------|-------------------|------------|----------|
| 6"         | BKR 1975# New Tie | Surface    | 170      |

9. GROUT OR OTHER SEALING MATERIAL

| Kind   | From (ft.) | To (ft.) |
|--------|------------|----------|
| Cement | Surface    | 170      |

Well construction completed on 4/16 1971

11. MISCELLANEOUS DATA

Yield test: 8 Hrs. at 10 GPM

Depth from surface to normal water level 250 ft.

Depth to water level when pumping 270 ft.

Well is terminated 10 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 4/22 1971

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Edwin W. Myers Registered Well Driller COMPLETE MAIL ADDRESS New albion Bk 55

Please do not write in space below

| COLIFORM TEST RESULT | GAS - 24 HRS. | GAS - 48 HRS. | CONFIRMED | REMARKS |
|----------------------|---------------|---------------|-----------|---------|
| 730                  |               |               |           |         |