

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

JUL 20 1972

12063

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Scott

2. LOCATION - 1/4 Section SE Section 36 Township 9N Range 3W 3. OWNER AT TIME OF DRILLING Windward Farms

OR - Grid or street no. Street name ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Boscobel, Wis., 53805

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
<u>1 1/2 miles</u>	C. I. TILE	C. I. TILE	SEWER CONNECTED INDEPENDENT	C. I. TILE

(Record answer in appropriate block)

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I. TILE								

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Cattle in pasture

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>42</u>	<u>6</u>	<u>42</u>	<u>460</u>	<u>Clay</u>	<u>Surface</u>	<u>10</u>	
						<u>limestone</u>	<u>10</u>	<u>150</u>	
						<u>sandstone</u>	<u>150</u>	<u>250</u>	
						<u>hard shalestone</u>	<u>250</u>	<u>410</u>	
						<u>sandstone</u>	<u>410</u>	<u>460</u>	

8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED			
Kind	From (ft.)	To (ft.)					
<u>Clay</u>	<u>Surface</u>	<u>10</u>	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Jetting with	<input type="checkbox"/> Air <input type="checkbox"/> Water
<u>Cement</u>	<u>10</u>	<u>42</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air			

11. MISCELLANEOUS DATA

Yield test: 5 Hrs. at 5 GPM

Well construction completed on 6-30-1972

Well is terminated 12 inches  above  below final grade

Depth from surface to normal water level 390 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 390 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 7-17-1972

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copsian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, R3 Box 84 Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>732</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------