

WELL CONSTRUCTOR'S REPORT

FEB 6 1970.

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

Well-6

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Haney

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
NE 1/4 of Sec. 1 T 9 N R 4 W

3. OWNER AT TIME OF DRILLING Lynn Bell Jr.

4. OWNER'S COMPLETE MAIL ADDRESS R2 Hays Mills, Wis. 54631

5. Distance in feet from well to nearest:
(Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER C.I.	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.
10'	18'	18'			

CLEAR WATER DRAIN C.I.	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
	65'		80'		120'	120'	70'	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	120	6	120	420	Clay	Surface	30
						broken limestone	30	190
						sandstone	190	240
						shalestone	240	380
						sandstone	380	420

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	120

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	30
Cement	30	120

11. MISCELLANEOUS DATA

Yield test: 6 Hrs. at 15 GPM

Well construction completed on 1-25-1970

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 310 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 320 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 2-3-1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boocabel, Wis 53805

Please do not write in space below

COLIFORM TEST RESULT <u>734</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------