

1. COUNTY Crawford CHECK ONE Town Village City NAME Haney

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
NW Part of Sec. 22 T 9N R 4W

3. OWNER AT TIME OF DRILLING
Sidney Brown

4. OWNER'S COMPLETE MAIL ADDRESS
R2 Gay Mills, Wis. 54631

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C. I.	TILE
12'	40'	40'					40'

CLEAR WATER DRAIN C. I.	TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
		78'			90'	200'	250'	50'	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10'	Surface	61	6"	61	400'	Clay & stone	Surface	25
						limestone	25	45
						Clay pockets	45	52
						hard limestone	52	210
						blue limestone	210	315
						sandstone	315	400

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6"	black-plain end new 19.18	Surface	61

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	25
Cement	25	61

11. MISCELLANEOUS DATA

Yield test: 10 Hrs. at 15 GPM

Well is terminated 20 inches above below final grade

Depth from surface to normal water level 360 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 365 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 3-4-1968

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
753				