

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Naney

2. LOCATION (Number and street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
S W 1/4 of Sec. 32 T 9 N R 4 W

3. OWNER AT TIME OF DRILLING  
Mr. & Mrs. Neil Kinder

4. OWNER'S COMPLETE MAIL ADDRESS  
R1 Steuben, Wis. 54657

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER C.I.	FLOOR DRAIN TILE	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
20'		35'	35'			35'

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		80'		90'		150'			

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	69	6	69	100	Clay	Surface	60
						sandstone	60	100

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	69

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	69
Cement	60	100

11. MISCELLANEOUS DATA  
 Yield test: 5 Hrs. at 15 GPM  
 Well construction completed on Oct. 12 - 1968  
 Well is terminated 11 inches  above  below final grade

Depth from surface to normal water level 70 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 70 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison, Wis. laboratory on: 10-23-1968

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Wesley Copier Registered Well Driller COMPLETE MAIL ADDRESS 53805 R3 Box 84. Boocohel, Wis.

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
759				