

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City NAME Seneca

2. LOCATION - 1/4 Section NW Section 3 Township 9N Range 5W 3. OWNER AT TIME OF DRILLING Kimmel Olson

OR - Grid or street no. Street name ADDRESS Gays Mills, WI

AND - If available subdivision name, lot & block no. POST OFFICE Wis., 54631

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	C. I.	C. I.	SEWER CONNECTED	C. I.
TILE	TILE	TILE	INDEPENDENT	TILE
<u>18'</u>	<u>40'</u>			<u>40'</u>

(Record answer in appropriate block)

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	<u>65'</u>			<u>65'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>190</u>	<u>6</u>	<u>190</u>	<u>360</u>	<u>Clay</u>	<u>Surface</u>	<u>12</u>
						<u>sandstone</u>	<u>12</u>	<u>110</u>
						<u>limestone</u>	<u>110</u>	<u>325</u>
						<u>sandstone</u>	<u>325</u>	<u>360</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>190</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>12</u>
<u>Cement</u>	<u>12</u>	<u>190</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary

Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 9-27- 1971

11. MISCELLANEOUS DATA

Yield test: 5 Hrs. at 12 GPM

Well is terminated 11 inches above below final grade

Depth from surface to normal water level 280 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 294 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 10-6- 1971

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Benneth Popian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>770</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------