

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

OCT 5 1976

WELL CONSTRUCTOR'S REPORT
 Form 3300-15
 Rev. 10-75

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Seneca

2. LOCATION SW 13 3N 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
Clarence L. Baker
 OR - Grid or Street No. Street Name 9 5 ADDRESS R 1

AND - If available subdivision name, lot & block No. POST OFFICE Says Mills, WI 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 25' Sanitary Bldg. Drain C.I. 30' Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 70' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>0</u> Surface	<u>265</u>	<u>6</u>	<u>265</u>	<u>320</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Soft Sand</u>	<u>0</u> Surface	<u>8</u>
<u>Sandrock</u>	<u>8</u>	<u>155</u>
<u>Clay</u>	<u>155</u>	<u>195</u>
<u>Limestone</u>	<u>195</u>	<u>240</u>
<u>Sandstone</u>	<u>240</u>	<u>320</u>

7. CASING, LINER, CURBING AND SCREEN
 Material, Weight, Specification & Method of Assembly

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>P.E. New Blacksteel 18.97</u>	<u>0</u> Surface	<u>265</u>
	<u>Valley Steel A-33</u>		
	<u>Pitless Adaptor</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>0</u> Surface	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>265</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 6 GPM

Depth from surface to normal water level 250 Ft.

Depth of water level when pumping 268 Ft. Stabilized Yes No

Well construction completed on Sept 11 1976

Well is terminated 10 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Sept. 27 1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address R 3 - Box 84 - Boscobel, WI 53805