

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH

Well 6

See Instructions on Reverse Side

1. County Crawford Town  Seneca Village  City  Check one and give name APR 22 1965  
 2. Location Section 27 Town 9 R 5 W Name of street and number of premise or Section, Town and Range numbers SANITARY ENGINEERING  
 3. Owner  or Agent  Frank Garvey Name of individual, partnership or firm  
 4. Mail Address R 70 Seneca, Wis. Complete address required  
 5. From well to nearest: Building 125 ft; sewer 150 ft; drain 150 ft; septic tank 160 ft; dry well or filter bed 165 ft; abandoned well 0 ft.

6. Well is intended to supply water for: Farm home

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	84	6	84	209

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6"	Standard wt.	0	84

9. GROUT:

Kind	From (ft.)	To (ft.)
Clay	0	15
Cement	15	84

11. MISCELLANEOUS DATA:

Yield test: 2 Hrs. at 5 GPM.  
 Depth from surface to water-level: 190 ft.  
 Water-level when pumping: 190 ft.  
 Water sample was sent to the state laboratory at:  
Madison on April 13 1965  
City

10. FORMATIONS:

Kind	From (ft.)	To (ft.)
Clay	0	15
broken sandrock	15	25
limestone	25	60
poor sandrock	60	70
solid sandrock	70	84

*This was a repair job - beyond this point I do not know*

Construction of the well was completed on:

4-13 1963

The well is terminated 10 inches  above, below  the permanent ground surface.

Was the well disinfected upon completion?

Yes  No

Was the well sealed watertight upon completion?

Yes  No

Signature Herminth Coppians  
 Registered Well Driller

R3 Box 36 Boscobel, Wis.  
 Complete Mail Address

Please do not write in space below

Rec'd APR 15 1965  
APR 19 1965  
 Ans'd \_\_\_\_\_  
 Interpretation SAFE BACTERIOLOGICALLY

No. 14602

10 ml 10 ml 10 ml 10 ml 10 ml

Gas—24 hrs. \_\_\_\_\_  
 48 hrs. \_\_\_\_\_  
 Confirm \_\_\_\_\_  
 B. Coli 00000  
 Examiner \_\_\_\_\_