

SEP 29 1975

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Seneca

2. LOCATION - 1/4 Section SE Section 27 Township 9N Range 5W 3. OWNER AT TIME OF DRILLING Mr. Rinehart Mischel
OR - Grid or street no. Street name ADDRESS R7D1

AND - If available subdivision name, lot & block no. POST OFFICE Eastman, Wis. 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE		
<u>150'</u>	<u>150'</u>							
CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
	<u>180'</u>			<u>200'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Farm home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>249</u>	<u>6</u>	<u>249</u>	<u>380</u>	<u>Clay</u>	<u>Surface</u>	<u>15</u>	
						<u>sandstone</u>	<u>15</u>	<u>125</u>	
						<u>limestone</u>	<u>125</u>	<u>200</u>	
						<u>soft sandstone</u>	<u>200</u>	<u>224</u>	
						<u>hard sandstone</u>	<u>224</u>	<u>380</u>	

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97</u>	<u>Surface</u>	<u>249</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>puddle clay</u>	<u>Surface</u>	<u>15</u>
<u>Cement</u>	<u>15</u>	<u>249</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 9 - 18 1975

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 6 GPM

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 260 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 274 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 9 - 24 - 1975

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel Wis., 53805

COLIFORM TEST RESULT 788 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS

REV. 3-71