

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman

2. LOCATION SE 1/4 NW 1/4 Section 21 Township 8N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Leonard W. Nunzeker

OR - Grid or Street No. Street of Road Name ADDRESS Rt. 1 Box 93

AND - If available subdivision name, lot & block No. POST OFFICE Eastman Wi. ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 25'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank
San.	Storm	C.I.	Other	Sewer	Sewage Sump	C.I.	Other				Seepage Pit	Seepage Bed	

Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well	Pump	Tank	Nonconforming Existing								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin		Other (Describe)
					Concrete Floor Only	Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: Private

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	296			
6	296	705			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	Now Blacksteel CAC ASTM A-53 Plain End #18.97 6x21 1280W	Surface	296

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Dirt & loose rock	Surface	13
Lime rock & crevice	13	147
Sand rock	147	190
Lime rock & crevice	190	289
Lime rock	289	475
Sandrock	475	565
Shale	565	705

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Pitless Adaptor	Surface	7
Cement	7	296

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 6-1 1987

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 1 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 610 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 645 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to MADISON laboratory on 6-30 1987

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Michael A. Peniston Registered Well Driller

Business Name and Complete Mailing Address CARDIAN well Drilling Inc.
R.R. 2 Boscobel WI. 53805