

WELL CONSTRUCTOR'S REPORT

Well-6

JUL 9 1970

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Seneca

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
SE 1/4 of Sec 27 T 9 N R 5 W

3. OWNER AT TIME OF DRILLING  
Michael F. Floyd Foley

4. OWNER'S COMPLETE MAIL ADDRESS  
R 7 D 1 Eastman, Wis. 54626

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
15'	C.I. 25'	TILE	C.I. TILE	SEWER CONNECTED INDEPENDENT
				25'

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C.I. TILE	60'		85'					

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Home

7. DRILLHOLE						10. FORMATIONS		
Dis. (in.)	From (ft.)	To (ft.)	Dis. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	282	6	282	400	Clay	Surface	30
						limestone	30	85
						soft sandstone	85	170
						limestone	170	350
						sandstone	350	400

8. CASING, LINER, CURBING, AND SCREEN			
Dis. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	282

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	30
Cement	30	282

11. MISCELLANEOUS DATA

Yield test: 5 Hrs. at 8 GPM

Well construction completed on 12-5-1969

Well is terminated 10 inches  above  below final grade

Depth from surface to normal water level 320 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 340 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 7-6-1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphouses, access pits, etc., should be given on reverse side.

SIGNATURE Benneth Copian Registered Well Driller COMPLETE MAIL ADDRESS R 3 Box 84 Boacohel, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>790</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------