

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

MAY 30 1979

| | | | | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------|---------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------|
| 1. COUNTY <u>Crawford</u> | | CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City | | Name <u>Seneca</u> | |
| 2. LOCATION | | 1/4 Section <u>14 of 23</u> | Section <u>9N</u> | Range <u>6W</u> | 3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE |
| OR - Grid or Street No. Street Name | | ADDRESS <u>Felipe Mahlman</u> | | ADDRESS <u>Lynville,</u> | |
| AND If available subdivision name, lot & block No. | | POST OFFICE <u>Wis. 54640</u> | | | |
| 4. Distance in feet from well to nearest: (Record answer in appropriate block) | | Building <u>8'</u> | Sanitary Bldg. Drain C.I. <u>City Sewer</u> Other | Sanitary Bldg. Sewer C.I. <u>75'</u> Other | Floor Drain Connected To: C.I. Sewer Other Sewer |
| Street Sewer San. Storm C.I. Other | | Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump | | Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench | |
| Privy Pet Waste Pit | | Pit: Nonconforming Existing Well Pump Tank | | Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit | |
| Temporary Manure Stack | | Watertight Liquid Manure Tank Solid Manure Storage Structure | | Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description) | |
| 5. Well is intended to supply water for: <u>Trailer home</u> | | | 9. FORMATIONS | | |
| 6. DRILLHOLE | | | Kind From (ft.) To (ft.) | | |
| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) |
| <u>10</u> | <u>0</u> Surface | <u>84</u> | <u>6</u> | <u>84</u> | <u>100</u> |
| | | | | | <u>Clay & stone</u> Surface <u>0</u> <u>70</u> |
| | | | | | <u>hard shalestone</u> <u>70</u> <u>90</u> |
| | | | | | <u>sandstone</u> <u>90</u> <u>100</u> |
| 7. CASING, LINER, CURBING AND SCREEN | | | 10. TYPE OF DRILLING MACHINE USED | | |
| Material, Weight, Specification & Method of Assembly | | | <input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water | | |
| Dia. (in.) | From (ft.) | To (ft.) | | | |
| <u>6</u> | <u>0</u> Surface | <u>84</u> | | | |
| <u>new black steel</u> | | | | | |
| <u>RE. 18.97</u> | | | | | |
| <u>A-53</u> | | | | | |
| <u>Valley Steel</u> | | | | | |
| <u>Morrison head</u> | | | | | |
| 8. GROUT OR OTHER SEALING MATERIAL | | | Well construction completed on <u>May 5 - 19 79</u> | | |
| Kind | | From (ft.) | To (ft.) | Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade | |
| <u>Clay</u> | | <u>0</u> Surface | <u>7</u> | Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| <u>Cement</u> | | <u>7</u> | <u>84</u> | Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| 11. MISCELLANEOUS DATA | | | Water sample sent to <u>Madison</u> laboratory on <u>5-22-19 79</u> | | |
| Yield Test: <u>3</u> Hrs. at <u>5</u> GPM | | | | | |
| Depth from surface to normal water level <u>70</u> Ft. | | | | | |
| Depth of water level when pumping <u>86</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | | | | |
| Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side. | | | | | |
| Signature <u>Kenneth Coplan</u> Registered Well Driller | | | Complete Mail Address <u>Boocobel, Wis., R3 Box 84 53805</u> | | |