

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

JUL 1 - 1974

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City NAME Seneca

2. LOCATION - 1/4 Section SE Section 1 Township 9N Range 6W
OR - Grid or street no. Street name
3. OWNER AT TIME OF DRILLING Paul W. Kaufman
ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Lynville, Wis. 54640

4. Distance in feet from well to nearest:
(Record answer in appropriate block)

| | | | | | | |
|----------------|---------------------|-------------------|----------------------------------|------------------------------|-------------------------|------------------------|
| BUILDING C. I. | SANITARY SEWER TILE | FLOOR DRAIN C. I. | FOUNDATION DRAIN SEWER CONNECTED | FOUNDATION DRAIN INDEPENDENT | WASTE WATER DRAIN C. I. | WASTE WATER DRAIN TILE |
| <u>8'</u> | <u>28'</u> | | | | | |

| | | | | | | | | |
|-------------------------|------------------|-------|-------------|------------------|------|------|----------------|-----------|
| CLEAR WATER DRAIN C. I. | SEPTIC TANK TILE | PRIVY | SEEPAGE PIT | ABSORPTION FIELD | BARN | SILO | ABANDONED WELL | SINK HOLE |
| | <u>54'</u> | | | <u>70'</u> | | | | |

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Trailer home

| 6. DRILLHOLE | | | | | | 9. FORMATIONS | | | |
|--------------|----------------|------------|------------|------------|------------|-------------------------|----------------|-----------|--|
| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) | Kind | From (ft.) | To (ft.) | |
| <u>10</u> | <u>Surface</u> | <u>53'</u> | <u>6</u> | <u>53</u> | <u>75'</u> | <u>Clay</u> | <u>Surface</u> | <u>12</u> | |
| | | | | | | <u>broken limestone</u> | <u>12</u> | <u>40</u> | |
| | | | | | | <u>hard shale stone</u> | <u>40</u> | <u>75</u> | |

| 7. CASING, LINER, CURBING, AND SCREEN | | | |
|---------------------------------------|--|----------------|-----------|
| Dia. (in.) | Kind and Weight | From (ft.) | To (ft.) |
| <u>6</u> | <u>new black steel plain end 18.97</u> | <u>Surface</u> | <u>53</u> |

| 8. GROUT OR OTHER SEALING MATERIAL | | | 10. TYPE OF DRILLING MACHINE USED | | |
|------------------------------------|----------------|-----------|--|---|---|
| Kind | From (ft.) | To (ft.) | <input type="checkbox"/> Cable Tool | <input type="checkbox"/> Direct Rotary | <input type="checkbox"/> Reverse Rotary |
| <u>Clay</u> | <u>Surface</u> | <u>12</u> | <input type="checkbox"/> Rotary - air w/drilling mud | <input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air | <input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water |
| <u>Cement</u> | <u>12</u> | <u>53</u> | Well construction completed on <u>6-8-</u> <u>1974</u> | | |

| 11. MISCELLANEOUS DATA | |
|--|--|
| Yield test: <u>2</u> Hrs. at <u>8</u> GPM | Well is terminated <u>16</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade |
| Depth from surface to normal water level <u>40</u> ft. | Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| Depth to water level when pumping <u>48</u> ft. | Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |

Water sample sent to Madison laboratory on: 6-26- 1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel Wis. 53805

COLIFORM TEST RESULT 806 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS