

NOV 3 1983

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman

2. LOCATION NW 1/4 Sec 30 Section 30 Township 8N Range 7W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Clarence Schufka

OR - Grid or Street No. Street or Road Name R6W? ADDRESS Villa Louis Rd

AND - If available subdivision name, lot & block No. POST OFFICE Prarie Du Chen WI 53821 ZIP CODE 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 56' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Clearwater Sump Holding Tank Septic Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 115' Manure Hopper or Retention or Pneumatic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	108	6	108	120
	Surface				

9. FORMATIONS

Kind	From (ft.)	To (ft.)
clay	0	20
sand rock	20	120

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	new black steel PSI 1200	Surface	108
	A-120 Valley Steel Pitless adapter		
	PE 18.90		

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 7-28 1983

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	108

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 80 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 83 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 10-26 1983

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Knochbaum Registered Well Driller Business Name and Complete Mailing Address Box 75 - Dons Well Drilling Base WI 53825