

# WELL CONSTRUCTOR'S REPORT

Well-6

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Seneca

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
NW 1/4 of Sec 14 T 9N R 6W

3. OWNER AT TIME OF DRILLING  
Ervin Skaszewski

4. OWNER'S COMPLETE MAIL ADDRESS  
RFD Lynville, Wis., 54640

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C.I.	TILE	C.I.	SEWER CONNECTED	INDEPENDENT

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C.I.	TILE							

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Country Home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	186	6	186	480	Clay	Surface	15
						limestone	15	160
						Clay	160	170
						limestone	170	390
						hard shalestone	390	460
						sandstone	460	480

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	186

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	15
Cement	15	186

11. MISCELLANEOUS DATA

Yield test: 4 Hrs. at 12 GPM

Well is terminated 10 inches  above  below final grade

Depth from surface to normal water level 390 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 402 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 2-15- 1971

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Roscoe, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
818				