

OCT 19 1979

NOTE:
 White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Seneca

2. LOCATION 1/4 Section SW Section 24 Township 9 N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 OR - Grid or Street No. Street Name ADDRESS Carl Fenehelm

AND -- If available subdivision name, lot & block No. POST OFFICE Lynxville

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 20 Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm C.I. Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 75

Privy Pet Waste Pit Nonconforming Existing Well Pump Tank Subsurface Pumphouse Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: None 9. FORMATIONS

6. DRILLHOLE			9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	82	Clay	Surface	20
6	82	104	sand	20	40
			gravel	40	55
			shale	55	82
			dolomite	82	104

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly From (ft.) To (ft.)
6" New Steel T & C Surface 15 82
A-53 grungtun

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)
Cement Surface 82

10. TYPE OF DRILLING MACHINE USED
 Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water
 Rotary-air w/drilling mud Rotary-hammer & air
 Rotary-w/drilling mud Reverse Rotary

Well construction completed on 5-9 1979

11. MISCELLANEOUS DATA
 Yield Test: 2 Hrs. at 20 GPM
 Depth from surface to normal water level 48 Ft.
 Depth of water level when pumping 60 Ft. Stabilized Yes No

Well is terminated 8 inches above below final grade
 Well disinfected upon completion Yes No
 Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Oct 4 1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Ralph J. Faberty Registered Well Driller

Complete Mail Address **Faberty Drilling Co., Inc.**
 1120 Broadway P.O. Box 409
 Platteville, Wisconsin 53818