

WELL CONSTRUCTORS REPORT

DEPARTMENT OF RESOURCE DEVELOPMENT APR 24 1970

Well 6

1. COUNTY CRANFORD CHECK ONE Town Village City NAME SENECA, WIS. SEP 1970

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
PART OF N.W. OF THE S.W. PART OF WEST 1/2 OF N.E. OF S.W. SEC. 24 - TWN. 9 RGE 8-W

3. OWNER AT TIME OF DRILLING MRS. MILDRED WOLCOTT (6)

4. OWNER'S COMPLETE MAIL ADDRESS R.F.D. 1 EASTMAN, WIS.

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING		SANITARY SEWER		FLOOR DRAIN		FOUNDATION DRAIN		WASTE WATER DRAIN	
C. I.	TILE	C. I.	TILE	C. I.	TILE	SEWER CONNECTED	INDEPENDENT	C. I.	TILE
	5'								

CLEAR WATER DRAIN		SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE								
		55'	none	75'	115'	none	none	none	none

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)
NONE

6. Well is intended to supply water for: HOME

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	131	6"	131	161	FILL	Surface	10	
						CLAY	10	70	
						BROWN LIME ROCK	70	80	
						SAND AND GREEN SHAL.	80	131	
						SAND STONE	131	160	

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	YOUNGSTOWN STEEL	Surface	131
	19.45 PER. FT.		
	6" DRIVE SHOE		
	PLAIN END CASING		
<i>New casing</i>			

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
NEAT CEMENT	Surface	131

11. MISCELLANEOUS DATA

Well construction completed on DEC. 12 1969

Yield test: 4 Hrs. at 12 GPM Well is terminated 12 inches above below final grade

Depth from surface to normal water level 95 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 100 ft. Well sealed watertight upon completion Yes No

Water sample sent to _____ laboratory on: 19

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Lewis Harris Registered Well Driller COMPLETE MAIL ADDRESS 327 N. MAIN. ST. PRAIRIE DU CHIEN, WIS.

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
<u>832</u>				