

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Clayton	
2. LOCATION OR - Grid or Street No. Street Name		1/4 Section SE Section 3 Township 10 N Range 3 W		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Edling Davig	
AND - If available subdivision name, lot & block No.		ADDRESS R7D		POST OFFICE Soldiers Grove, Wis. 54655	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building 40'		Sanitary Bldg. Drain C.I. Other	
		Sanitary Bldg. Sewer C.I. Other		Floor Drain Connected To: C.I. Sewer Other Sewer	
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.	
				Sewage Sump Clearwater Sump	
				Clearwater Sump	
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing	
				Barn Gutter	
				Animal Barn Pen	
				Animal Yard 100'	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit 100'	
				Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
				Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)	
				Other (Give Description)	
5. Well is intended to supply water for: Farm home				9. FORMATIONS	
6. DRILLHOLE				Kind	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)				From (ft.) To (ft.)	
10 Surface 0 150 6 150 310				Clay Surface 0 40	
				soft sandstone 40 140	
				hard sandstone 140 180	
				limestone 180 250	
				sandstone 250 310	
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly					
Dia. (in.)		From (ft.)		To (ft.)	
6		Surface 0		150	
new black steel P.E. 18.97 A-53					
Valley Steel Pitless adaptor					
8. GROUT OR OTHER SEALING MATERIAL					
Kind		From (ft.)		To (ft.)	
Clay		Surface 0		7	
Cement		7		150	
10. TYPE OF DRILLING MACHINE USED					
<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary-air w/drilling mud		<input type="checkbox"/> Jetting with	
<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary-hammer w/drilling mud & air		<input type="checkbox"/> Air	
<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary		<input type="checkbox"/> Water	
Well construction completed on 8-20- 19 77					
11. MISCELLANEOUS DATA					
Yield Test: 3 Hrs. at 5 GPM		Well is terminated 12 inches		<input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below	
Depth from surface to normal water level 220 Ft.		Well disinfected upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth of water level when pumping 235 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Water sample sent to Madison laboratory on 8-29- 19 77					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature Kenneth Coyman Registered Well Driller			Complete Mail Address R3 Box 84 Boscobel Wis. 53805		