JUL 28 1976

State of Wisconsin
Department of Natural Resources
Box 450
Madison, Wisconsin 53701

NOTE:
White Copy – Division's Copy
Green Copy – Driller's Copy
Yellow Copy – Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300–15
Rev. 10–75

1. COUNTY: Crawford

CHECK (✓) ONE: [X] Town [ ] Village [ ] City — Name: Clayton

2. LOCATION: ¼ Section: SW; Section: 9; Township: 10-N; Range: 3W

OR – Grid or Street No.: ; Street Name:

AND – If available subdivision name, lot & block No.:

3. NAME [ ] OWNER [ ] AGENT AT TIME OF DRILLING CHECK (✓) ONE: Mike Hankin

ADDRESS: Rt. 2

POST OFFICE: Soldiers Grove, Wis. 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain C.I.	Sanitary Bldg. Drain Other	Sanitary Bldg. Sewer C.I.	Sanitary Bldg. Sewer Other	Floor Drain Connected To: C.I. Sewer	Floor Drain Connected To: Other Sewer	Storm Bldg. Drain C.I.	Storm Bldg. Drain Other	Storm Bldg. Sewer C.I.	Storm Bldg. Sewer Other
18										

Street Sewer San.	Street Sewer Storm	Other Sewers C.I.	Other Sewers Other	Foundation Drain Connected to: Sewer	Sewage Sump	Clearwater Dr.	Clearwater Sump	Sewage Sump C.I.	Sewage Sump Other	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	
											50		Seepage Pit	
													Seepage Bed	
													Seepage Trench	

Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom Nonconforming Existing	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
		Well									
		Pump									
		Tank									

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)

5. Well is intended to supply water for: Pvt. Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	43	6	43	170

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	SCED 40 18:97PE.	Surface	43
	ASTM-A-53		
	U.S. Steel		
	Pitless Adapter		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Backfill	Surface	8
Cement Grout	8	43

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Brown Sand	Surface	5
Clay	5	9
Brown Sandstone	9	55
Hard Brown Sandstone	55	132
Soft Brown Sandstone	132	170

10. TYPE OF DRILLING MACHINE USED

[X] Cable Tool [ ] Rotary-air w/drilling mud [ ] Rotary-w/drilling mud [ ] Rotary-hammer w/drilling mud & air [ ] Rotary-hammer & air [ ] Reverse Rotary [ ] Jetting with [ ] Air [ ] Water

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 10 GPM

Depth from surface to normal water level 120 Ft.

Depth of water level when pumping 125 Ft. Stabilized [X] Yes [ ] No

Well construction completed on 7/8/ 19 76

Well is terminated 18 inches [X] above [ ] below final grade

Well disinfected upon completion [X] Yes [ ] No

Well sealed watertight upon completion [X] Yes [ ] No

Water sample sent to State laboratory on 7/8/76 19 76

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature: Albin Herbeck
856 Albin Herbeck #482
Registered Well Driller

Complete Mail Address: Box 136 Richland Center, Wis. 53581