

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Clayton

2. LOCATION 1/4 Section NW Section 11 Township 10 N Range 3 W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Steve Otis

OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Soldiers Grove, Wisc. 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 8' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 85' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter 200' Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Farm home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	121	6	121	280

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay & Stone	Surface	100
limestone	100	170
shalestone	170	250
sandstone	250	280

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	121

new black steel P.E. 18.97 A-53 Keystone pipe Pitless adapter

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-air w/drilling mud  Rotary-w/drilling mud  Rotary-hammer w/drilling mud & air  Rotary-hammer & air  Reverse Rotary  Jetting with  Air  Water

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	8
Cement	8	121

Well construction completed on 9-13-1979

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 10 GPM

Depth from surface to normal water level 180 Ft.

Depth of water level when pumping 210 Ft. Stabilized  Yes  No

Well is terminated 10 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 9-18-1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boocobol, Wisc. R2 Box 4 53805