

WELL CONSTRUCTOR'S REPORT

Well-6

JUL 9 1970

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Clayton

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
SW 1/4 of Sec. 13 T10N R13W

3. OWNER AT TIME OF DRILLING Clifford Murphy

4. OWNER'S COMPLETE MAIL ADDRESS RFB Soldiers Grove, Wis 54655

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
15'	25'	25'				

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
		100'			125'				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	52	6	52	100	Clay	Surface	20
						Clay & loose stone	20	40
						hard shale stone	40	80
						sandstone	80	100

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	53

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	20
Cement	20	53

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 7 GPM

Well construction completed on 5-27-1970

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 60 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 65 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 7-6-1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>864</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------