

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

MAR 31 1980

1. COUNTY <b>Crawford</b>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			Name <b>Scott</b>	
2. LOCATION OR - Grid or Street No. Street Name		1/4 Section <b>SW</b>	Section <b>16</b>	Township <b>T9N</b>	Range <b>R3W</b>	3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <b>Robert J. Bloedow</b>
AND - If available subdivision name, lot & block No.		ADDRESS <b>RFD</b>				
		POST OFFICE <b>Boscobel, WI 53805</b>				
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <b>20'</b>	Sanitary Bldg. Drain C.I. Other	Sanitary Bldg. Sewer C.I. Other	Floor Drain Connected To: C.I. Sewer Other Sewer	Storm Bldg. Drain C.I. Other
		Street Sewer San. Storm	Other Sewers C.I. Other	Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.	Sewage Sump C.I. Other	Clearwater Sump
		Septic Tank <b>60'</b>		Holding Tank		
		Sewage Absorption Unit <b>60'</b> Seepage Pit Seepage Bed Seepage Trench				
Privy	Pet Waste Pit	Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing		Barn Gutter
Animal Barn Pen	Animal Yard	Silo With Pit		Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)	
5. Well is intended to supply water for: <b>Country Home</b>				9. FORMATIONS		
6. DRILLHOLE				Kind		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	From (ft.) To (ft.)
<b>10</b>	<b>Surface</b>	<b>80</b>	<b>6</b>	<b>80</b>	<b>200</b>	<b>Clay</b> <b>Surface</b> <b>10</b>
						<b>Sandstone</b> <b>10</b> <b>40</b>
						<b>Hard Limestone</b> <b>40</b> <b>200</b>
7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification						
Dia. (in.)	& Method of Assembly		From (ft.)	To (ft.)		
<b>6</b>	<b>new black steel R.E. 18.97</b>		<b>Surface</b>	<b>80</b>		
	<b>A-53</b>					
	<b>Keystone Pipe</b>					
	<b>Pitless Adapter</b>					
8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED		
Kind		From (ft.)	To (ft.)			
<b>Clay</b>		<b>Surface</b>	<b>8</b>			
<b>Cement</b>		<b>8</b>	<b>80</b>			
				<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary		
				Well construction completed on <b>3-10</b> 19 <b>80</b>		
11. MISCELLANEOUS DATA				Well is terminated <b>10</b> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade		
Yield Test: <b>3</b> Hrs. at <b>5</b> GPM		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
Depth from surface to normal water level <b>130</b> Ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
Depth of water level when pumping <b>185</b> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No						
Water sample sent to <b>Madison</b>				laboratory on <b>3-24</b> 19 <b>80</b>		
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.						
Signature <b>Philip &amp; Caplan</b> Registered Well Driller				Complete Mail Address <b>Rt. 2, Box 4 - Boscobel, WI 53805</b>		