

1. COUNTY <i>Crawford</i>		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		NAME <i>Clayton</i>				
2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.) <i>SW 1/4 of Sec. 21 T10N R3W</i>								
3. OWNER AT TIME OF DRILLING <i>Mr. & Mrs. Wm. Meier</i>								
4. OWNER'S COMPLETE MAIL ADDRESS <i>R2 Soldiers Grove, Wis. 54655</i>								
5. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING C. I.	SANITARY SEWER C. I.	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTER INDEPENDENT	WASTE WATER DRAIN C. I.		
		<i>20'</i>	<i>60'</i>	<i>60'</i>		<i>60'</i>		
CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
	<i>60</i>		<i>75'</i>					
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)								

6. Well is intended to supply water for: *Home & Store*

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<i>10</i>	<i>Surface</i>	<i>40</i>	<i>6</i>	<i>40</i>	<i>525</i>	<i>Clay</i>	<i>Surface</i>	<i>15</i>	
						<i>limestone</i>	<i>15</i>	<i>218</i>	
8. CASING, LINER, CURBING, AND SCREEN									
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)						
<i>6</i>	<i>black plain end new 19.18</i>	<i>Surface</i>	<i>40</i>			<i>sandstone</i>	<i>218</i>	<i>305</i>	
						<i>blue limestone</i>	<i>305</i>	<i>410</i>	
						<i>sandstone</i>	<i>410</i>	<i>525</i>	
9. GROUT OR OTHER SEALING MATERIAL									
Kind	From (ft.)	To (ft.)							
<i>Clay</i>	<i>Surface</i>	<i>15</i>							
<i>Cement</i>	<i>15</i>	<i>40</i>							

11. MISCELLANEOUS DATA		Well construction completed on <i>Sept. 17 - 1967</i>	
Yield test: <i>20</i> Hrs. at <i>22</i> GPM	Well is terminated <i>10</i> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade		
Depth from surface to normal water level <i>400</i> ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth to water level when pumping <i>425</i> ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <i>Madison</i>	laboratory on: <i>Sept. 25 1967</i>		

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Kenneth Coplan</i>	COMPLETE MAIL ADDRESS <i>R3 Box 84 Boscobel, Wis. 53805</i>
Registered Well Driller	

Please do not write in space below

COLIFORM TEST RESULT <i>870</i>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------